



# Modification de l'échelle de classification européenne pour l'eau – 08/2012

ancien/nouveau

| L/ (m <sup>2</sup> .an) | 1                             | 2                           | 3                           | 4                                 |                       |
|-------------------------|-------------------------------|-----------------------------|-----------------------------|-----------------------------------|-----------------------|
|                         | <b>Crèche/Jardin d'enfant</b> | <b>Enseignement général</b> | <b>Ecoles avec piscines</b> | <b>Enseignement professionnel</b> | <b>Administration</b> |
| <b>A</b>                | X ≤ 200/50                    | X ≤ 100/60                  | X ≤ 12500                   | X ≤ 125/50                        | X ≤ 100/30            |
| <b>B</b>                | 200/50 < X ≤ 375/250          | 100/60 < X ≤ 225/150        | 12500 < X ≤ 25000           | 125/50 < X ≤ 200/145              | 100/30 < X ≤ 200/170  |
| <b>C</b>                | 375/250 < X ≤ 550/450         | 225/150 < X ≤ 350/240       | 25000 < X ≤ 37500           | 200/145 < X ≤ 275/240             | 200/170 < X ≤ 300/240 |
| <b>D</b>                | 550/450 < X ≤ 725/650         | 350/240 < X ≤ 475/330       | 37500 < X ≤ 50000           | 275/240 < X ≤ 350/335             | 300/240 < X ≤ 400/310 |
| <b>E</b>                | 725/650 < X ≤ 900/850         | 475/330 < X ≤ 600/420       | 50000 < X ≤ 62500           | 350/335 < X ≤ 425/430             | 400/310 < X ≤ 500/380 |
| <b>F</b>                | 900/850 < X ≤ 1075/1050       | 600/420 < X ≤ 725/510       | 62500 < X ≤ 75000           | 425/430 < X ≤ 500/525             | 500/380 < X ≤ 600/450 |
| <b>G</b>                | X > 1075/1050                 | X > 725/510                 | X > 75000                   | X > 500/525                       | X > 600/450           |

| L/ (m <sup>2</sup> .an) | 5                              | 6                              | 7                     | 8                             | 9                          | 10                       |
|-------------------------|--------------------------------|--------------------------------|-----------------------|-------------------------------|----------------------------|--------------------------|
|                         | <b>Piscine (l'utilisateur)</b> | <b>Installations sportives</b> | <b>Dépôt</b>          | <b>Lieux de rassemblement</b> | <b>Dispensaire médical</b> | <b>Centre de secours</b> |
| <b>A</b>                | X ≤ 80                         | X ≤ 100/40                     | X ≤ 100/30            | X ≤ 50/30                     | X ≤ 500/80                 | X ≤ 350                  |
| <b>B</b>                | 80 < X ≤ 125                   | 100/40 < X ≤ 225/110           | 100/30 < X ≤ 250/110  | 50/30 < X ≤ 125/100           | 500/80 < X ≤ 750/510       | 350 < X ≤ 500            |
| <b>C</b>                | 125 < X ≤ 170                  | 225/110 < X ≤ 350/180          | 250/110 < X ≤ 400/190 | 125/100 < X ≤ 200/170         | 750/510 < X ≤ 1000/940     | 500 < X ≤ 650            |
| <b>D</b>                | 170 < X ≤ 215                  | 350/180 < X ≤ 475/250          | 400/190 < X ≤ 550/270 | 200/170 < X ≤ 275/240         | 1000/940 < X ≤ 1250/1380   | 650 < X ≤ 800            |
| <b>E</b>                | 215 < X ≤ 260                  | 475/250 < X ≤ 600/320          | 550/270 < X ≤ 700/350 | 275/240 < X ≤ 350/310         | 1250/1380 < X ≤ 1500/1810  | 800 < X ≤ 950            |
| <b>F</b>                | 260 < X ≤ 305                  | 600/320 < X ≤ 725/390          | 700/350 < X ≤ 850/430 | 350/310 < X ≤ 425/380         | 1500/1810 < X ≤ 1750/2240  | 950 < X ≤ 1100           |
| <b>G</b>                | X > 305                        | X > 725/390                    | X > 850/430           | X > 425/380                   | X > 1750/2240              | X > 1100                 |

| L/ (m <sup>2</sup> .an) | 11                        | 12                        | 13              | 14                | 15               | 16              |
|-------------------------|---------------------------|---------------------------|-----------------|-------------------|------------------|-----------------|
|                         | <b>Habitat Collectif</b>  | <b>Habitat individuel</b> | <b>Commerce</b> | <b>Restaurant</b> | <b>Industrie</b> | <b>Hôpitaux</b> |
| <b>A</b>                | X ≤ 500/300               | X ≤ 500                   | X ≤ 100         | X ≤ 500           | X ≤ 350          | X ≤ 500         |
| <b>B</b>                | 500/300 < X ≤ 750/550     | 500 < X ≤ 800             | 100 < X ≤ 200   | 500 < X ≤ 750     | 350 < X ≤ 480    | 500 < X ≤ 750   |
| <b>C</b>                | 750/550 < X ≤ 1000/800    | 800 < X ≤ 1100            | 200 < X ≤ 300   | 750 < X ≤ 1000    | 480 < X ≤ 610    | 750 < X ≤ 1000  |
| <b>D</b>                | 1000/800 < X ≤ 1250/1050  | 1100 < X ≤ 1400           | 300 < X ≤ 400   | 1000 < X ≤ 1250   | 610 < X ≤ 740    | 1000 < X ≤ 1250 |
| <b>E</b>                | 1250/1050 < X ≤ 1500/1300 | 1400 < X ≤ 1700           | 400 < X ≤ 500   | 1250 < X ≤ 1500   | 740 < X ≤ 870    | 1250 < X ≤ 1500 |
| <b>F</b>                | 1500/1300 < X ≤ 1750/1550 | 1700 < X ≤ 2000           | 500 < X ≤ 600   | 1500 < X ≤ 1750   | 870 < X ≤ 1000   | 1500 < X ≤ 1750 |
| <b>G</b>                | X > 1750/1550             | X > 2000                  | X > 600         | X > 1750          | X > 1000         | X > 1750        |